



MODEL	FILL	CAPACITY
700B-2P	2" MPT	19.22 gallons for UL Listed Boxes
700B-3P	3" MPT	
700B-4P	4" MPT	
750B-2P	2" FPT	
750B-3P	3" FPT	
750B-4P	4" FPT	
770B-2P*	2" comp boot	
770B-3P*	3" comp boot	
770B-4P*	4" comp boot	

"S" Following any model no. designates stainless steel construction.  
 \*\* Cutout and bolt holes pre-drilled for UL Listed flexible entry boot (supplied with unit).

- MATERIALS:**
- SPILL CONTAINMENT CABINET:**  
16GA STEEL MINIMUM (ALT "S" 16GA MINIMUM STAINLESS STEEL)
  - MOUNTING BRACKETS:**  
1/4" X 2" STEEL FLAT BAR (ALT "S" S/S SCH 40 MIN)
  - FILL AND DRAIN PIPE FITTINGS:**  
ALL STEEL, SCH 40 MIN (ALT "S" S/S SCH 40 MIN)
  - LOCK TABS:**  
3/16" STEEL WITH 1/2" DIA PADLOCK HOLE (ALT "S" 3/16" STAINLESS STEEL)
  - COATING:**  
"P" POWDER COAT ZINC RICH EPOXY INTERIOR AND EXTERIOR W/2<sup>ND</sup> EXT. POLYESTER (ALT "S" STAINLESS STEEL, NO COATING)

**CAUTION**  
 FLAMMABLE OR COMBUSTIBLE LIQUIDS/VAPORS MAY BE PRESENT. KEEP AWAY SPARKS, FLAME, IGNITION SOURCES. EXTINGUISH SMOKING MATERIALS. FOR USE WITH PROPERLY VENTED STORAGE VESSELS. KEEP DOOR CLOSED AND LOCKED WHEN NOT IN USE.

This drawing and design are proprietary to BAKER INDUSTRIES NORTHWEST, and may not be copied or duplicated in whole or in part without the written permission of BAKER INDUSTRIES NW.

#700 SERIES GROUND LEVEL SPILL CONTAINMENT TANK MOUNTING BRACKET MODELS

BAKER INDUSTRIES NORTHWEST  
 12428 Highway 99 South, Unit 56  
 Everett, Washington 98204-5502  
 Tel: (425) 212-3169 • FAX: (425) 353-6788 • e-mail: [ben@bakerindnw.com](mailto:ben@bakerindnw.com)  
[www.bakerindustriessouthwest.com](http://www.bakerindustriessouthwest.com)

REV		DRAWN	CHECKED	DATE
REV		LRG	RBW	03-28-95
REV		SLG	LRG	03-05-06
REV	UL REVISION 2019	BSD	NDD	01/28/19

