

MATERIALS:

- SPILL CONTAINMENT BOX:
 16GA STEEL, ALL WELDED
 AND LEAK TESTED
- FITTINGS: ALL STEEL SCH 40
- COATING:

POWDERCOAT ZINC RICH EPOXY INTERIOR AND EXTERIOR WHITE, WITH A 2ND EXTERIOR COATING OF POLYESTER.

CAUTION

FLAMMABLE OR COMBUSTIBLE LIQUIDS/VAPORS MAY BE PRESENT. KEEP AWAY SPARKS, FLAME, IGNITION SOURCES. EXTINGUISH SMOKING MATERIALS. FOR USE WITH PROPERLY VENTED STORAGE VESSELS. KEEP DOOR CLOSED AND LOCKED WHEN NOT IN USE.

DATE

This drawing and design are proprietary to BAKER INDUSTRIES NORTHWEST, and may not be copied or duplicated in whole or in part without the written permission of BAKER INDUSTRIES NW.

CHECKED



#700 SERIES GROUND LEVEL SPILL CONTAINMENT IN-WALL OR THROUGH-WALL INSTALLATIONS

BAKER INDUSTRIES NORTHWEST

12428 Highway 99 South, Unit 56
Everett, Washington 98204-5502
Tel:(425)212-3169 • FAX:(425)353-6788 • e-mail: larry@bakerindnw.com
www.bakerindustriesnorthwest.com

REV	LRG	RBW	04-04-97
REV	SLG	LRG	03-05-06
REV			

DRAWN